

MESA COUNTY GENERAL TESTING SCHEDULE

Item	Type of Test	Minimum Test Frequency
Subgrade and Embankment Compaction	Moisture-Density Curve	1 per soil type
	In-Place Density	1 per 2000 cu. yds. or fraction thereof
Aggregate Base Course or Subbase Course	Gradation	1 per 2000 tons or 1 per 1000 cu. yds. or fraction thereof
	Moisture-Density Curve	1 per source
	In-Place Density	1 per 2000 tons or 1 per 1000 cu. yds. or fraction thereof
Hot Bituminous Pavement	Asphalt Content	1 per 1000 tons or fraction thereof mix produced
	In-Place Density	1 per 1250 linear ft. per roadway or fraction thereof mix placed
	Gradation	Aggregate - 1 per 2000 tons or fraction thereof mix produced
Sidewalks and Curbing	Compressive Strength	1 set of cylinders (5) per 1000 sq. yds. or fraction thereof
	Slump	1 per set of cylinders
	Air Content	1 per 1000 sq. yds. or fraction thereof
Utility Trench Backfill Compaction	In-Place Density	1 per 200 cu. yds. or fraction thereof
Manholes/Structures Compaction	In-Place Density	1 per structure per 2 ft. vertical lift

For all other testing requirements please refer to the Mesa County Standard Specifications for Road & Bridge Construction